


2ND FLOOR
SCALE: 1/8" = 1'-0"



FIRE ALARM SYMBOLS	
SYMBOL	DESCRIPTION
[FACP]	FIRE ALARM CONTROL PANEL
[FAGAP]	FIRE ALARM GRAPHIC ANNUNCIATOR PANEL
[NACP]	NOTIFICATION APPLIANCE CONTROL PANEL
[FACB]	FIRE ALARM TERMINAL CABINET
[M]	MANUAL STATION
[SD]	SMOKE DETECTOR
[SRD]	SMOKE DETECTOR - PLENUM RETURN AIR
[SDS]	DUCT SMOKE DETECTOR
[H]	HEAT DETECTOR
[SWF]	SPRINKLER WATERFLOW (CONNECTED TO MONITOR MODULE)
[ST]	SPRINKLER TAMPERS (CONNECTED TO MONITOR MODULE)
[CM]	CONTROL MODULE
[M]	MONITOR MODULE
[DM]	DUAL MONITOR MODULE
[R]	RELAY MODULE
[RI]	REMOTE INDICATOR LIGHT/TEST SWITCH
[S]	STROBE - WALL MOUNT
[CS]	STROBE - CEILING MOUNT
[HWS]	HORN/STROBE - WALL MOUNT
[HCS]	HORN/STROBE - CEILING MOUNT
[HW]	HORN - WALL MOUNT
[J]	JUNCTION BOX
[TBD]	DENOTES DEVICE IS TO BE DEMOLISHED
[ETR]	DENOTES DEVICE IS EXISTING TO REMAIN
[TBR]	DENOTES DEVICE IS TO BE REPLACED
[N]	DENOTES DEVICE IS NEW
[#cd]	DENOTES STROBE CANDELA RATING
[NAC#]	DENOTES NACP# AND CIRCUIT#
[WP]	DENOTES DEVICE IS WEATHERPROOF

STR STROBE CIRCUITS
CLASS B 14-2 TP FLP
NOTES:
All ceiling heights are 10' or less U.O.N.

These drawings have been reviewed by:
Donte M. Jackson, SET
for compliance with local regulations.
Signature: [Signature] Date: 7/28/2022
NICET Certificate # 137084 (Exp. 10/1/2022)
Fire Alarm Systems - Level IV

2ND FLOOR FIRE ALARM			
CORPORATE OAKS II			
607 HERNDON PARKWAY HERNDON, VA 20170			
 AN ARCHKEY SOLUTIONS COMPANY 7915 MARGOLM RD CLINTON, MD 20735 (301) 858-8400			
REV. #	DESCRIPTION	BY	DATE
1.	FIRE REVIEW COMMENTS	DJ	8/25/22
2.			
3.			
4.			
DRAWN BY: XX	CHECKED BY: XX	DATE: 7/28/2022	SCALE: 1/8" = 1'-0"
		SHEET # 42	DRAWING # FA-03