



Ector County Health Department

221 N. Texas Ave
Odessa, TX 79761
(432) 498-4141

Notice of Approval & License to Operate an On-Site Sewage Facility PERMIT #: 12156

Location: 1850 FM 866 N., Odessa, TX 79763-
Lot 2 Block 1 Wildcatter Place
Owner: Rigoberto Marrero
Mailing address: 3612 Roosevelt, Midland, TX 79703-

Proposed Improvement: Hobby Shop

Type of OSSF:	Treatment Type:	Septic
	Disposal Type:	Leaching Chambers
	Maximum Flow:	160 Gallons per Day
	Primary Tank Size	1000 Gallons
	Clarifier Tank Size	Gallons
	Pump Tank Size	Gallons
	Drainfield:	16 - 5.0 Feet Long Panels
	Drainfield Dimensions:	16 x 3 feet

This serves to notify all persons that the on-site sewage facility owned by the above has been approved, satisfying design, construction, and installation requirements of the Texas Commission on Environmental Quality (TCEQ).

This On-Site Sewage Facility (OSSF) Permit and License to Operate is issued for the operation of the above-identified on-site sewage facility. State standards do not guarantee that an OSSF will perform satisfactorily under all conditions. It is the responsibility of the owner to maintain and operate the facility in a satisfactory manner.

The issuance of this license to operate an OSSF shall only indicate that the facility meets the minimum requirements for issuance of this license.

Any modifications to the size of the business or alteration of the OSSF requires a new permit. Water supply lines are required to be placed at least 10 feet from sewer lines and any part of the OSSF. Water lines shall not cross sewer lines unless they have been engineered to meet TAC Chapter 290. Failure to maintain these separation distances will result in revocation of your Permit and License to Operate.

Additional Requirements:

Kelby Upchurch,

Agency

May 30, 2023

Date