

have been
 in
 provision
 conform to
 distances of
ARCHITECT

10949

- ELECTRICAL REVIEW NOTES:**
1. All wiring, equipment, etc. supplied from panel in the East space that extends into the West space must be removed.
 2. Receptacles above the kitchen counter or sink or within 6' of the sink must be G.F.I. protected.
 3. Receptacles exposed above the store front window require a minimum of 4".
 4. The electrical panel cannot be located on a demising wall.

EXISTING
 ADJACENT
 TENANT
 NUC

PETAL SPACE NUC

FIVE STAR NUCS SPACE 650

RELOCATE EXISTING FIXTURES
 TO NEW LOCATIONS

THESE FIXTURES ARE TENANT IMPROVEMENT

JB FOR
 SIGNAGE

REFER TO
 ENLARGED PLAN

EXIST.
 ELECT
 PANEL

LAND
 LORD
 WORK

EXIT

EXIT
 LIGHTING

10654
 Approx

401
 Approx

30' x 70' = 2100 sq ft
 Approx

30'
 Approx

