

EMERGENCY LIGHTING REQUIRED

IBC SEC. 1006 MEANS OF EGRESS ILLUMINATION

WHEN A BUILDING IS OCCUPIED, THE MEANS OF EGRESS SHALL BE ILLUMINATED AT AN INTENSITY OF NOT LESS THAN 1 FOOT CANDLE AT THE FLOOR LEVEL. THE POWER SUPPLY SHALL NORMALLY BE PROVIDED BY THE PRIMARY ELECTRICAL SUPPLY.

NOTE: EMERGENCY LIGHTING SHALL BE SUPPLIED AT THE EXTERIOR EXIT DISCHARGE AND IN ALL BATHROOMS, CHANGING ROOMS, AND TOILET FACILITIES.

COORDINATE PLACEMENT OF EXIT SIGNAGE WITH THE BUILDING INSPECTOR

IBC SEC. 1004.3, CONNECTED SPACES

WHEN A BUILDING, OR PORTION OF A BUILDING, IS REQUIRED TO BE ACCESSIBLE, AN ACCESSIBLE ROUTE SHALL BE PROVIDED TO EACH PORTION OF THE BUILDING, TO ACCESSIBLE BUILDING ENTRANCES CONNECTING ACCESSIBLE PEDESTRIAN WALKWAYS AND THE PUBLIC WAY.

NOTHING IS TO PREVENT THE USE OF FIRE-RESISTANT HARDWARE IF BALANCED DOORS ARE USED AND PANIC HARDWARE IS REQUIRED, THE PANIC SHALL BE PUSH-PAD TYPE AND THE PAD SHALL NOT EXTEND MORE THAN ONE-HALF THE WIDTH OF THE DOOR MEASURED FROM THE LATCH SIDE.

KEY PLAN

